

If you would like to do a further
Search of this document.

Please click on the icon below.



Title 15R

WATER AND SEWERS

Chapter:

15R.36 Sewer Services and Fees

15R.40 Sewer Discharge Requirements

Exhibits: (Exhibits following Chapter 15R.36)

A Sewer Service Area, Effective January 5,1993

NOTE: Footnotes are numbered throughout the text and are located at the end of this title.

Chapter 15R.36

SEWER SERVICES AND FEES

Section:

15R.36.010 Sewer service area map.

15R.36.010 Sewer service area map.

A. All of that area delineated on the attached map, entitled “sewer service area, effective January 5, 1993,” incorporated by reference into this Chapter as Exhibit “A,” is established as the city “sewer service area” pursuant to Section 15.36.025 of this code. Such map shall be known as the “sewer service area” map.

B. The official copy of the map shall be maintained in the office of the general services director. The copy included in this section shall be for reference only.

(Res. No. 86 84-85 §1, Res. No. 157 84-85 §1, Res. No. 82 85-86, Res. No. 92 85-86 §1, Res. No. 10 86-87 §1, Res. No. 81 86-87 §1, Res. No. 162 86-87 §1, Res. No. 109 92-93, Res. No. 110 92-93, Res. No. 111 92-93, Res. No. 139 92-93, Res. No. 133 95-96 §7, Res. No. 113-07)

Chapter 15R.40

SEWER DISCHARGE REQUIREMENTS

Section:

15R.40.010 Specific pollutant - Local limitations.

15R.40.010 Specific pollutant - Local limitations.

Industrial discharge into the city’s sewer system shall not exceed the specific pollutant limitations pursuant to Section 15.40.060 of this code. The specific pollutant limitations are as follows:

A. For Industrial Wastewater Dischargers Connected to the City Sewer System Prior to 9/1/98

1. Local Limitations, Monthly Maximum (milligrams per liter):

<u>Parameter:</u>	<u>Concentration:</u>
Benzene	0.13
Carbondisulfide	0.06
Chloroethane (ethylchloride)	0.42
Chloroform	0.42
Chloromethane	0.007
1,2-Dichorobenzene	3.74
1,3-Dichorobenzene	18.20
1,4-Dichorobenzene	3.54
Dichloromethane(methylene chloride)	4.15
Ethylbenzene	1.59
Hexachloroethane	0.96
Tetrachloroethylene	0.53
Tolulene	1.35
BOD	To be determined by the General Services Director
TSS	To be determined by the General Services Director
Antimony	7.043
Arsenic (daily max.)	0.266
Beryllium	2.2
Cadmium	0.17
Chromium (total)	1.71
Mercury	0.017
Nickel	1.19
Selenium	0.05
Cyanide (daily max.)	0.290

2. Discharger Specific Limitations, Monthly Maximum (milligrams per liter):

Permit Holder	Copper	Lead	Silver	Zinc (daily max.)
Lares Research	2.07	0.43	0.24	2.61
Prisma Power Coating	2.07	0.43	0.24	2.61
2nd Operations	2.6	1.55	1.74	3.03
Valley Industrial Coating	2.07	0.43	0.24	2.61
Enloe Hospital	2.6	1.55	1.74	3.03
Lifetouch	2.6	1.55	1.74	3.03
Mooney Farms	2.6	1.55	1.74	3.03
Sierra Nevada Brewery	2.6	1.55	1.74	3.03
Mission Industries	2.6	1.55	1.74	3.03
Wrex Products	0.42	0.39	1.74	1.14
CSU Chico	2.07	0.43	0.24	2.61

B. Industrial Wastewater Dischargers Connected to the City Sewer System On or After 9/1/98

Local Limitations, Monthly Maximum (milligrams per liter):

<u>Parameter:</u>	<u>Concentration:</u>
Benzene	0.13
Carbondisulfide	0.06
Chloroethane (ethylchloride)	0.42
Chloroform	0.42
Chloromethane	0.007
1,2-Dichorobenzene	3.74
1,3-Dichorobenzene	18.20
1,4-Dichorobenzene	3.54
Dichloromethane (methylene chloride)	4.15
Ethylbenzene	1.59
Hexachloroethane	0.96
Tetrachloroethylene	0.53
Tolulene	1.35
BOD	To be determined by the General Services Director
TSS	To be determined by the General Services Director
Antimony	7.043
Arsenic	0.266
Beryllium	0.681
Cadmium	0.038
Chromium (total)	0.360
Copper	0.638
Lead	0.389
Mercury	0.017
Nickel	0.259

Chico Municipal Code

SEWER DISCHARGE REQUIREMENTS

Selenium	0.053
Silver	0.349
Zinc	0.776
Cyanide	0.290

(Res. No. 85 98-99, Res. No. 113-07)